

CERTIFICATE OF CONFORMITY

This is to certify that

Difuze (S) Pte. Ltd.

31 Woodlands Close
#07-13 Woodlands Horizon
SINGAPORE 737855
UEN: 202019746M

has been assessed and found to meet the requirements of PLS - Scheme Type 2 for

Product:	Air Distribution Duct / Ducting
Brand:	URSA AIR
Model:	Alu-Alu P5858
Country of Origin:	Spain
Product Details:	Mineral glass wool board Tested on the marked Kraft aluminium face Wool Density: 75kg/m ³ Overall density: 91kg/m ³ (Classification: B-s1, d0)
Test Standard(s):	EN 13501-1:2018
Test Report(s):	KAS No. J231127002-2R1

This certificate issued in accordance with SCDF Fire Code requirements.



Eric Law

Head of Certification

For and on behalf of Element Testing Services (S) Pte Ltd

Certificate number:
22C0574

Issue number: 01

Date of initial certification:
26 May 2022

Date of revision:
19 April 2024

Expiry date:
25 May 2027

Page 1 of 1

Issuing Office: 249 Jalan Boon Lay Singapore 619523
Registered Office: 249 Jalan Boon Lay Singapore 619523
UEN 198004219D

This certificate remains the property of Element Testing Services (S) Pte Ltd.

This certificate and all copies or reproductions of the certificate shall be returned to Element Testing Services (S) Pte Ltd or destroyed if requested.

Further clarification regarding the scope of this certificate and verification of the certificate is available through Element Testing Services (S) Pte Ltd or at the above address or at <https://www.certificationsingapore.element.com/>

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation number PD-2010-12. This Certificate is part of a full report and should be read in conjunction with it.

For further information on Element Testing Services (S) Pte Ltd activities covered by SAC accreditation can be accessed at: <https://www.sac-accreditation.gov.sg/accredited-org/certified-cab-companies>

