

CERTIFICATE OF CONFORMITY

This is to certify that

Difuze (S) Pte. Ltd.

31 Woodlands Close
#07-13 Woodlands Horizon
SINGAPORE 737855
UEN: 202019746M

has been assessed and found to meet the requirements of PLS - Scheme Type 2 for

Product:	Air Distribution Duct / Ducting
Brand:	URSA AIR
Model:	Zero P8858
Country of Origin:	Spain
Product Details:	Mineral glass wool board Tested on the monogram printed pattern aluminium foil face Area Density: 2.44kg/m ² (Rating: Class 0)
Test Standard(s):	BS 476-6:1989+A1:2009 BS 476-7:1997
Test Report(s):	Sirim No. 2025FE0440, 2025FE0441

This certificate issued in accordance with SCDF Fire Code requirements.



Eric Law

Head of Certification

For and on behalf of Element Testing Services (S) Pte Ltd

Certificate number:
25C0871

Issue number: 01

Date of initial certification:
18 September 2025

Date of revision:
-

Expiry date:
17 September 2030

Page 1 of 1

Issuing Office: 249 Jalan Boon Lay Singapore 619523
Registered Office: 249 Jalan Boon Lay Singapore 619523
UEN 198004219D

This certificate remains the property of Element Testing Services (S) Pte Ltd.

This certificate and all copies or reproductions of the certificate shall be returned to Element Testing Services (S) Pte Ltd or destroyed if requested.

Further clarification regarding the scope of this certificate and verification of the certificate is available through Element Testing Services (S) Pte Ltd or at the above address or at <https://www.certificationsingapore.element.com/>

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation number PD-2010-12. This Certificate is part of a full report and should be read in conjunction with it.

For further information on Element Testing Services (S) Pte Ltd activities covered by SAC accreditation can be accessed at: <https://www.sac-accreditation.gov.sg/accredited-org/certified-cab-companies>

