

CERTIFICATE OF CONFORMITY

This is to certify that

Difuze (S) Pte. Ltd.

31 Woodlands Close
#01-27 Woodlands Horizon
SINGAPORE 737855
UEN: 202019746M

has been assessed and found to meet the requirements of PLS - Scheme Type 2 for

Product:	Air Distribution Duct / Ducting
Brand:	DS PANEL
Model:	DSP-20, DSP-30
Country of Origin:	China
Product Details:	PIR Pre-Insulated Duct Panel Area Density: 1.20kg/m ² Tested on the aluminium foil face (Rating: Class 0)
Test Standard(s):	BS 476-6:1989 + A1:2009 BS 476-7:1997
Test Report(s):	Sirim No. 2026FE0343, 2026FE0344 ETS No. CL-ETS-2026FE0343, CL-ETS-2026FE0344

This certificate issued in accordance with SCDF Fire Code requirements.



Sherly Wijaya
Head of Certification

For and on behalf of Element Testing Services (S) Pte Ltd

Certificate number:
26C0906

Issue number: 01

Date of initial certification:
13 May 2026

Date of revision:
-

Expiry date:
12 May 2031

Page 1 of 1

Issuing Office: 4010 Ang Mo Kio Avenue 10 #03-12 Techplace 1 Singapore 569626
Registered Office: 4010 Ang Mo Kio Avenue 10 #03-12 Techplace 1 Singapore 569626
UEN 198004219D

This certificate remains the property of Element Testing Services (S) Pte Ltd.

This certificate and all copies or reproductions of the certificate shall be returned to Element Testing Services (S) Pte Ltd or destroyed if requested.

Further clarification regarding the scope of this certificate and verification of the certificate is available through Element Testing Services (S) Pte Ltd or at the above address or at <https://certificationsingapore.element.com>

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation number PD-2010-12. This Certificate is part of a full report and should be read in conjunction with it.

For further information on Element Testing Services (S) Pte Ltd activities covered by SAC accreditation can be accessed at:
<https://sac-accreditation.gov.sg>